



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/81729

Date: 25-01-2022

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: MAHILA KALA SHIKSHA AUR SEVA KENDRA
44, Ramkamal Street, Kolkata- 700023.

Sub: Fire Safety Certificate for existing construction of the occupancy of Kitchen for Mid Day Meal Situated at Ground floor under Asbestos Shed in the name of "MAHILA KALA SHIKSHA AUR SEVA KENDRA" at the Premises No. – 44, Ramkamal Street, Ward No.- 76, Borough- IX, Kolkata- 700023.

This is in reference to your application no. 0125189218700332 dated 13-12-2021 regarding the Fire Safety Certificate for existing construction of the occupancy of Kitchen for Mid Day Meal Situated at Ground floor under Asbestos Shed in the name of "MAHILA KALA SHIKSHA AUR SEVA KENDRA" at the Premises No. – 44, Ramkamal Street, Ward No.- 76, Borough- IX, Kolkata- 700023.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

However to up-keep the Fire Safety Measures; the following safety measures need to be incorporated/and maintained.—

1. Driveway must be free of any obstruction for easy movement of Fire Appliances. No Parking will be allowed in the Drive Way.
2. No Interior finish decoration of building inside the Kitchen shall be allowed.
3. To eliminate of fire hazard, Good Housekeeping both inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the entire building shall have to be carefully checked for any wear and tear in them, particularly line above false ceiling & ducts.
5. The Exit Sign and fire notice shall be maintained from fading and dust sedimentation and prepared and displayed at all venerable place.

6. The employees and Security staffs shall be conversant with installed Fire Fighting Equipments of the building and operate in the event of fire and testing.
7. Mock Fire Practice and Evacuation Drill shall be performed periodically with participation of all the occupant of the building.
8. Special training to employees and staffs shall be give for carrying the ambulant(s) to the safer place in the event of any exigency.
9. Meter and Main room shall be removed to outside of the building and be protected with CO2 or D.C.P. Modular Fire Extinguishers.
10. Fire License shall have to be obtained for storing and/processing with LPG and/ other highly inflammable articles.
11. If required the old electrical lines shall have to be replaced with new ones in M. S. conduit laying continuously bonded to the earth.
12. The Fire Safety Audit to be conducted at a regular interval and to be recorded in the Fire Prevention Maintenance Register.

The Fire Safety Certificate Is valid for three years and has to be renewed triennially from the date of issue of this letter.

Triennially a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the Life & Fire Safety Arrangements and Installations of the Building.

Signature valid

Digitally signed by SAROJ
KUMAR BA
Date: 2022.01.25 22:21:48 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services